



LG&E Energy ~~XXXX~~ LLC*
220 West Main Street (40202)
P.O. Box 32030
Louisville, Kentucky 40232

C

March 1, 2004

RECEIVED

MAR 0 1 2004

**PUBLIC SERVICE
COMMISSION**

Mr. Thomas M. Dorman
Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

Dear Mr. Dorman:

Re: Case No. 99-441 **Sample Meter Testing Pilot Plan**

The PSC Order in Case Number 99-441 allowed for a new sample-testing plan for participating electric utilities. This order required these same utilities to submit an annual report to the Commission.

Pursuant to the October 25, 2000 Revised Amended Sample Meter Testing Pilot Plan, Appendix A, Section I (4) and Appendix A, Section II (D)(3)(b), **Kentucky Utilities Company** submits the following:

The Certified Test Results of all new meters received
(Attachment A)

2002 Statistical Sampling Test Results and Summary
(Attachment B)

If you have any questions please do not hesitate to contact me.

Sincerely,

Marty J. Reinert
Regulatory Analyst II
Regulatory Affairs

Attachments

Cc: Mr. Dennis Hildenbrand



KU 2003 SAMPLE ELECTRIC METER SUMMARY

SAMPLE

In-Service Population	457,205	Divided into 65 Lots
Sample Quantity	4,037	
Meters Tested	4,033	
Meters Not Tested	4	
Failed Lots	0	
Failed Lot Meters	0	

DETAIL OF METERS NOT TESTED

Lost/Stolen

L124245	I60-4	Not located, presumed lost
C163211	J	Not located, presumed lost
C349732	J5-9	Not located, presumed lost

Open Potential Coil

W122865	J4-2
---------	------